

CERTIFICATE OF COMPLIANCE

Certificate Number 20170130-EX16258
Report Reference EX16258-20131121
Issue Date 2017-JANUARY-30

Issued to: DUYAR VANA MAKINA SAN VE TIC A S
Osmangazi Mahallesi 2653
Sokak No 7
Esenyurt
34522 Istanbul TURKEY

**This is to certify that
representative samples of**

DRAIN FITTINGS, SPECIAL TYPE
See addendum page

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

UL 258 Outline for Shutoff Valves for Trim and Drain
Purposes
ULC/ORD C258-03 Shutoff Valves for Trim And Drain
Purposes for Fire Protection Service
UL 199 Automatic Sprinklers for Fire-Protection Service
(Calibration test only)

Additional Information:

See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20170130-EX16258
Report Reference EX16258-20131121
Issue Date 2017-JANUARY-30

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Model Y-4030 test and drain fitting in the following nominal sizes, discharge coefficients and rated pressures

Size, in.	Nominal K-Factor, gpm/(psi) ^{1/2}	Rated Pressure, psig
1, 1-1/4, 1-1/2, 2	5.6	300
1, 1-1/4, 1-1/2, 2	8.0	300



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

