

## CERTIFICATE OF CONSTANCY OF PERFORMANCE

### 2809 - CPR – F0036

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

#### **Model Y-4010 Wet Alarm Valves**

Sizes 2½, 3, 4, 6, and 8 inch NPS

(DN65, DN80, DN100, DN150 and DN200)

Maximum rated working pressure 300psi (2065kPa)

placed on the market under the name or trade mark of

#### **Duyar Vana Makina San ve Tic AS**

Osmangazi Mah 2653 Sk No. 7/1

Kirac-Esenyurt, Istanbul 34522

Turkey

and produced in the manufacturing plant(s)

#### **Duyar Vana Makina San ve Tic AS**

Osmangazi Mah 2653 Sk No. 7/1

Kirac-Esenyurt, Istanbul 34522

Turkey

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

### **EN 12259-2:1999 including Amendments A1:2001, A2:2005 and Corrigendum AC:2002**

under system 1 for the performances set out in this certificate (see Examination Report PR456139 dated 22<sup>nd</sup> July 2022) are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

### **constancy of performance of the construction product(s)**

This certificate was first issued on 26<sup>th</sup> August 2022 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Issue 1, Dublin, dated 26<sup>th</sup> August 2022

Page 1 of 1

F CPR 028(Dec/2020)

Richard Zammitt

Certification Manager

On behalf of FM Approvals Europe Limited  
(PR456139)



This certificate remains the property of FM Approvals and has been issued in accordance with FM Approvals CPR Certification Scheme.